
RAWL-125, -150, -180, -240 WIRING SCHEMATIC
(10, 12.5, 15 & 20 TON)



COMPONENT CODE

CC	COMPRESSOR CONTACTOR
CCH	CRANKCASE HEATER
COMP	COMPRESSOR
CT	CONTROL TRANSFORMER
DISC	DISCONNECT SWITCH
FC	FAN MOTOR CONTACTOR
GND	GROUND
HR	HEATER RELAY
HPC	HIGH PRESSURE CONTROL
LAC	LOW AMBIENT CONTROL
LPC	LOW PRESSURE CONTROL
MS	METAL STRIP
OFM	OUTDOOR FAN MOTOR
RC	RUN CAPCITOR
R	RELAY
TB	TERMINAL BLOCK
TH	THERMOSTAT
TDC	TIME DELAY CONTROL
THM	MOTOR SAFETY THERMOSTAT
TOR	THERMAL OVERLOAD RELAY
WN	WIRE NUT

NOTES:

1. REPLACEMENT WIRE & FUSES MUST BE SAME TYPE & SIZE AS ORIGINAL.
2. UNIT MUST BE PERMANENTLY GROUNDED & CONFORM TO N.E.C. & LOCAL CODES.
3. MAXIMUM IN RUSH VA NOT TO EXCEED 92 VA.
4. MINIMUM WIRE SIZE BASED ON 75 DEGREES C INSULATION COPPER WIRE.

WIRING INFORMATION

LINE VOLTAGE
- -FACTORY STANDARD
- -FACTORY OPTION
- -FIELD INSTALLED

LOW VOLTAGE
- -FACTORY STANDARD
- -FACTORY OPTION
- -FIELD INSTALLED

REPLACEMENT WIRE
- -MUST BE THE SAME SIZE AND TYPE OF INSULATION AS ORIGINAL (105°C MIN.)

WARNING
- -CABINET MUST BE PERMANENTLY GROUNDED AND CONFORM TO I.E.C., N.E.C., C.E.C., AND LOCAL CODES AS APPLICABLE.

WIRE COLOR CODE

BK	BLACK	O	ORANGE
BR	BROWN	PR	PURPLE
BL	BLUE	R	RED
G	GREEN	W	WHITE
GY	GRAY	Y	YELLOW

WIRING SCHEMATIC

CONDENSING UNIT

10, 12-1/2, 15 & 20 TON

208-230, 460, 575, 3PH 50 & 60 HZ

380, 3PH, 60 HZ

DR. BY	APP. BY	DATE	DWG. NO.	REV
MGR		11-14-00	90-42663-08	05

DWG. NO. 90-42663-08 REV 05