





COMPONENT CODE

BR	BLOWER RELAY	LAC	LOW AMBIENT COOLING CONTROL
CC	COMPRESSOR CONTACTOR	LC	LIMIT CONTROL
CCH	CRANKCASE HEATER	LPC	LOW PRESSURE CONTROL
COMP	COMPRESSOR	MRLC	MAN. RESET LIMIT CONTROL
CT	CONTROL TRANSFORMER	NPC	NEG. PRESSURE CONTROL
FLMS	FLAME SENSOR	OBD	ON BOARD DIAGNOSTICS
GL	GROUND LUG	OFM	OUTDOOR FAN MOTOR
GND	GROUND	OPT	OPTIONAL
GV	GAS VALVE	PL	PLUG
HPC	HIGH PRESSURE CONTROL	RC	RUN CAPACITOR
IBM	INDOOR BLOWER MOTOR	RES	RESISTOR
IBM CB	INDOOR BLOWER MOTOR CONTROL BOARD	SC	START CAPACITOR
IDM	INDUCED DRAFT MOTOR	SE	SPARK ELECTRODE
IFC	ITEGRATED FURNACE CONTROL	SR	START RELAY
HGS	HOT GAS SENSOR	TDC	TIME DELAY CONTROL
			WIRE NUT

NOTES:

1. MAIN UNIT TRANSFORMER PRIMARY LEADS: 60 HZ. RED-COMMON BLUE-208 V BLACK-230 V INTERCHANGE BLACK & BLUE LEADS FOR 208 V TRANSFORMER OPERATION.
2. MOTORS & COMPRESSOR THERMALLY PROTECTED.
3. CONNECTORS SUITABLE FOR USE WITH COPPER CONDUCTORS ONLY.
4. CONNECT FIELD WIRING IN GROUNDED RAINTIGHT CONDUIT TO 60 HZ FUSED DISCONNECT.
5. LOW VOLTAGE CIRCUIT IS N.E.C. CLASS 2 WITH A CLASS 2 TRANSFORMER 24 VOLT, 50/60 HERTZ SUPPLIED.
6. REPLACEMENT FUSES MUST BE SAME TYPE & SIZE AS ORIGINAL.

WIRING INFORMATION

LINE VOLTAGE
- -FACTORY STANDARD
- -FACTORY OPTION
- -FIELD INSTALLED

LOW VOLTAGE
- -FACTORY STANDARD
- -FACTORY OPTION
- -FIELD INSTALLED

REPLACEMENT WIRE
- -MUST BE THE SAME SIZE AND TYPE OF INSULATION AS ORIGINAL (105 C° MIN.)

WARNING
- -CABINET MUST BE PERMANENTLY GROUNDED AND CONFORM TO I.E.C., N.E.C., C.E.C. AND LOCAL CODES AS APPLICABLE.

WIRE COLOR CODE

BK	BLACK	GY	GRAY	R	RED
BR	BROWN	O	ORANGE	W	WHITE
BL	BLUE	PK	PINK	Y	YELLOW
G	GREEN	PR	PURPLE		

ELECTRICAL WIRING DIAGRAM

2.0 - 5.0 TON GAS/ELECTRIC
2-STAGE COMPRESSOR AND
INTEGRATED FURNACE CONTROL
208/230V, 1 - PHASE

DWG. NO.	REV
90-23626-16	01

DR. BY	APP. BY	DATE	DWG. NO.	REV
JRJ		1-18-07	90-23626-16	01